


FIRE RATED WALLS
 1 HR RATED

boomerang DESIGN
 rethink, repurpose, results

CHARLOTTE
 201 S. Washington St., Suite 200
 Charlotte, NC 28208
 704/956-6000

RALEIGH
 6131 Falls of Neuse Rd., Suite 204
 Raleigh, NC 27609
 919/373-6400

LEWISTON
 1070 S. Lake Dr., Suite 1
 Lewiston, NC 28119
 910/516-0207



- GENERAL NOTES:**
- ALL FIRE ALARM WIRING SHALL BE IN MINIMUM 3/4" CONDUIT.
 - SMOKE DETECTORS LOCATED AT MAGNETIC DOOR OPENERS SHALL BE CENTERED AT DOORWAY AT NO GREATER THAN 5'-0" FROM DOOR OPENING.
 - LOCATIONS OF NOTIFICATION APPLIANCE CABINETS (NAC) AND AMPLIFIER CABINETS (AMP) SHALL BE COORDINATED CLOSELY FOR PROPER CLEARANCES AND ACCESSIBILITY.
 - ALL 120V POWER FOR NAC PANELS AND AMPLIFIER CABINETS SHALL BE PROVIDED BY THE ELECTRICAL CONTRACTOR FROM THE NEAREST AVAILABLE 120/208 VOLT PANEL. BREAKERS FOR THOSE CIRCUITS SHALL HAVE RED BREAKER LOCKS.
 - FOR FIRE PROTECTION DEVICES (I.E. TAMPER SWITCHES, FLOW SWITCHES, ETC.) REFER TO FIP-SERIES FIRE PROTECTION DRAWINGS AND FIRE PROTECTION CONTRACTOR SHOP SUBMITTAL DRAWINGS PRIOR TO ANY ROUGH-IN.
 - EXCEPT WHERE SHOWN ON PLANS OR ABSOLUTELY NECESSARY (MUST BE APPROVED BY DESIGN TEAM), ALL CONDUITS AND PIPING SHALL BE CONCEALED IN BULKHEADS AND ABOVE CEILINGS AND NOT ROUTED THROUGH OPEN CEILINGS. REFER TO ARCHITECTURAL REFLECTED CEILING PLANS FOR THE LOCATION OF OPEN CEILINGS. WHEN CONDUITS ARE REQUIRED TO BE RUN EXPOSED, THEY ARE TO RUN TIGHT TO STRUCTURE AND BE PAINTED TO MATCH THE STRUCTURE.

- KEYNOTES:**
- FIRE PROTECTION FLOOR CONTROL VALVE ASSEMBLY. COORDINATE WITH FIRE PROTECTION CONTRACTOR.
 - SMOKE DETECTORS ARE REQUIRED IN EACH ELEVATOR LOBBY, MACHINE ROOM AND EACH SPRINKLER HEAD LOCATION IN HOISTWAY. ONLY THESE DETECTORS, WHEN ACTIVATED, SHALL PUT THE ELEVATOR IN FIREMAN'S RECALL OPERATION.
 - COORDINATE SPRINKLER BELL VOLTAGE WITH FIRE PROTECTION CONTRACTOR PRIOR TO ANY ROUGH-IN.
 - THESE HEAT DETECTORS SIGNAL THE SHUNT TRIP BREAKER TO TRIP, REMOVING POWER FROM THE ELEVATOR. THE ACTIVATION OF SMOKE DETECTORS REFERRED TO IN NOTE 2 CAPTURES THE ELEVATOR PRIOR TO THE ACTIVATION OF THE HEAT DETECTORS SO THAT MAIN LINE POWER IS REMOVED. HEAT DETECTORS SHALL BE INSTALLED AT EACH SPRINKLER LOCATION.

1 FIRST FLOOR FIRE ALARM PLAN
 1/8" = 1'-0"

pdcc
 Progressive Design Collaborative, Inc.
 3101 Poplarwood Court, Suite 320
 Raleigh, North Carolina 27604
 919-790-9989
 License# C-0183
 PROJECT #23015

COOPER ACADEMY A & R
 PROJECT TITLE
 "CLIENT'S PROJECT" # - XXX



- THESE DRAWINGS ARE THE SOLE PROPERTY OF THE STATE OF NORTH CAROLINA. THE USE OF THESE DRAWINGS MUST COMPLY WITH GOOD STATE OF NORTH CAROLINA STANDARD FORM OF AGREEMENT BETWEEN OWNER AND DESIGNER.
- MATERIALS, DIMENSIONS AND ALL OTHER CONDITIONS WHICH ARE NOT OTHERWISE SPECIFIED ON THIS DRAWING SHALL BE CONTROLLED BY HAVING THE SAME MEANINGS AS SIMILARLY INDICATED CONDITIONS WHICH ARE MORE FULLY DEFINED ELSEWHERE ON THIS PROJECT OR OTHER DRAWINGS OF THIS PROJECT.
- DO NOT SCALE OFF DIMENSIONS.

NO.	DATE	DESCRIPTION
1	02/28/2024	ADDENDUM 01

BID SET
 PROJECT PHASE
2307
 BOOMERANG DESIGN PROJECT NUMBER
02.07.2024
 DRAWING RELEASE DATE

FIRST FLOOR FIRE ALARM PLAN
 SHEET TITLE
E402
 SHEET

2/19/2024 4:54:56 PM