



- GENERAL NOTES:**
- A. ALL FIRE ALARM WIRING SHALL BE IN MINIMUM 3/4" C.
 - B. SMOKE DETECTORS AT DOORS WITH ELECTROMAGNETIC HOLDERS SHALL BE CENTERED ON DOORS AND WITHIN 5'-0" OF DOORS.
 - C. FIRE ALARM DEVICES LOCATED IN ZONE 1 AREAS SHALL BE CONNECTED TO NOTIFIER NFS 640 ADDRESSABLE SYSTEM.
 - D. FIRE ALARM DEVICES LOCATED IN ZONE 2 AREA SHALL BE CONNECTED TO NOTIFIER VOICE-EVAC SYSTEM, LOCATED IN NEW CLASSROOM ADDITION.
 - E. ALL PULLSTATIONS SHALL HAVE LEXAN COVERS.

**COOPER ACADEMY
A & R**
PROJECT TITLE

"CLIENT'S PROJECT" # - XXX



02/19/2024
TBTUKOVICH@PDCENGINEERS.COM



1. THESE DRAWINGS ARE THE SOLE PROPERTY OF THE STATE OF NORTH CAROLINA. THE USE OF THESE DRAWINGS MUST COMPLY WITH GOOD STATE OF NORTH CAROLINA STANDARD FORM OF AGREEMENT BETWEEN OWNER AND DESIGNER.
2. MATERIALS, DIMENSIONS AND ALL OTHER CONDITIONS WHICH ARE NOT OTHERWISE SPECIFIED ON THIS DRAWING SHALL BE CONTROLLED BY AVOIDING THE SAME MEANING AS SIMILARLY INDICATED CONDITIONS WHICH ARE MORE FULLY DEFINED ELSEWHERE ON THIS PROJECT OR OTHER DRAWINGS OF THIS PROJECT.
3. DO NOT SCALE OFF DIMENSIONS.

NO.	DATE	DESCRIPTION
1	02/28/2024	ADDENDUM 01

BID SET
PROJECT PHASE
2307
BOOMERANG DESIGN PROJECT NUMBER
02.07.2024
DRAWING RELEASE DATE

**ALT. 2 CONNECTOR &
ALT. 3 CORRIDOR
RENOVATION - FIRE
ALARM PLAN**
SHEET TITLE

E704
SHEET

1 ALT. 2 CONNECTOR ADDITION & ALT. 3 CORRIDOR RENOVATION - FIRE ALARM
1/8" = 1'-0"

2/19/2024 3:33:15 PM