



<

<

PANEL JL (ALTERNATE #2)																					
CKT	LOAD TYPE	LOAD KVA	DESCRIPTION	C	PH	N	G	CB	PHASE			CB	PH	N	G	C		DESCRIPTION	LOAD KVA	LOAD TYPE	CKT
									A	B	C										
1	R	0.540	RECEPT - CO1, CO2	3/4"	10	10	10	20	0.815			20	12	12	12	3/4"		LTS - EXTERIOR (NOTE 1)	0.275	L	
3	R	0.900	RECEPT - CO2, CO4	3/4"	10	10	10	20		1.961		20	12	12	12	3/4"		LTS - CO1-CO4 (NOTE 1)	1.961	L	
5	O	0.540	RECEPT-EXTERIOR	3/4"	10	10	10	20			2.460	20	10	10	10	3/4"		WHEELCHAIR LIFT	1.920	O	6
7	O		SPARE					20	0.000			20						SPARE		O	8
9	O		SPARE					20	0.000			20						SPARE		O	10
11	O		SPARE					20			0.000	20						SPARE		O	12
13	O		SPARE					20	0.000			20						SPARE		O	14
15	O		SPARE					20		0.000		20						SPARE		O	16
17	O		SPARE					20			0.000	20						SPARE		O	18
19	H	0.828		3/4"	10	N/A	10	15	1.404			15	10	N/A	10	3/4"		FC-2-ALT-2	0.576	H	20
21	H	0.828	FC-1-ALT-2							1.404									0.576	H	22
23	H	0.828								1.404									0.576	H	24
LOAD TOTAL:									2.22	3.37	3.150										
LOAD TYPE									CONNECTED	DEMAND											
(R) RECEPTACLES									1.98	100%	1.98										
(M) MOTOR									0.00	100%	0.00										
(H) HVAC									4.21	100%	4.21										
(L) LIGHTING									1.34	125%	1.67										
(O) OTHER									1.92	100%	1.92										
(K) KITCHEN EQUIP.									0.00	100%	0.00										
TOTAL									9.45	104%	9.78										
FED FROM: EXISTING MDP																					
MOUNT: FLUSH																					
NEMA: 1																					
PROVIDE DOOR WITH LOCK AND HINGED TRIM. PROVIDE COPPER BUSS BARS AND BOLT ON BREAKERS.																					
<b>PANEL TOTALS</b>																					
Phase A          2.287            KVA         19.1    AMP																					
Phase B          3.484            KVA         29.0    AMP																					
Phase C          4.001            KVA         33.3    AMP																					

NOTES:  
  
1. GROUND ALL EMERGENCY LIGHTS.  
2.  
3.  
4.

<

PANEL BL1																														
CKT	LOAD TYPE	LOAD KVA	DESCRIPTION	C	PH	N	G	B	PHASE			CB	PH	N	G	C	DESCRIPTION	LOAD KVA	LOAD TYPE	CKT										
								A	B	C																				
1	S	8.500	PANEL BL2	SEE POWER RISER	125			10.734			125	SEE POWER RISER					PANEL BL3	2,234	S	2										
3	S	9.920							12.274										2,354	S	4									
5	S	9.807								12.207										2,400	S	6								
7	O								0.000													0	8							
9	O		SPARE		100				0.000		30	10	10	10	3/4"		SPD		O	10										
11	O									0.000													0	12						
13	O									0.000													0	14						
15	O		SPARE		100				0.000								SPACE		O	16										
17	O									0.000													0	18						
19	O									0.000														0	20					
21	O		SPARE					20	0.000								SPACE	O	22											
23	O		SPARE					20		0.000							SPACE	O	24											
25	O		SPARE					20	0.000								SPACE	O	26											
27	O		SPARE					20		0.000							SPACE	O	28											
29	O		SPARE					20			0.000						SPACE	O	30											
31	H	0.728	CU-1	3/4"	10	N/A	10	0.728			20						SPARE		O	32										
33	H	0.728								0.728													0.728					SPARE	O	34
35	H	0.728								0.728																		SPARE	O	36
37	H	0.728	CU-2	3/4"	10	N/A	10	0.728			20						SPARE		O	38										
39	H	0.728								0.728																		SPARE	O	40
41	H	0.728	CU-3	3/4"	10	N/A	10			0.728	20						SPARE	O	42											
LOAD TOTAL:								12.19	13.73	13.86																				
LOAD TYPE								CONNECTED	DEMAND											FED FROM: TRANSFORMER TB										
(R) RECEPTACLES								23.96	72%	16.53									MOUNT: SURFACE											
(M) MOTOR								0.00	100%	0.00									NEMA: 1											
(H) HVAC								4.84	100%	4.84																				
(L) LIGHTING								1.80	125%	2.25																				
(O) OTHER								9.89	100%	9.89																				
(K) KITCHEN EQUIP								0.00	100%	0.00																				
TOTAL								39.58	85%	33.50									PROVIDE DOOR WITH LOCK AND HINGED TRIM. PROVIDE COPPER BUSS BARS AND BOLT ON BREAKERS.											
NOTES:																	PANEL TOTALS													
1.																	10.318													
2.																	11.621													
3.																	11.564													
4.																														

<

PANEL BL3

CKT	LOAD TYPE	LOAD KVA	DESCRIPTION	C	PH	N	G	CB	PHASE			CB	PH	N	G	C	DESCRIPTION	LOAD KVA	LOAD TYPE	CKT
1	R	0.400	RECEPT - EXTERIOR	3/4"	12	12	12	20	0.634			15	10	NA	10	3/4"	ACU-1, ACU-2	0.234	H	2
3	R	0.720	RECEPT - 605	3/4"	12	12	12	20	0.954									0.234	H	4
5	R	0.600	RECEPT - 605	3/4"	12	12	12	20		0.600		20					SPARE		O	6
7	R	0.600	RECEPT - 605	3/4"	12	12	12	20	0.600			20					SPARE		O	8
9	R	0.600	RECEPT - 605	3/4"	12	12	12	20		0.600		20					SPARE		O	10
11	O	1.000	DATA RACK - 605	3/4"	12	12	12	20		1.000		20					SPARE		O	12
13	O	1.000	DATA RACK - 605	3/4"	12	12	12	20	1.000			20					SPARE		O	14
15	O	0.800	AMPLIFIER CABINET (NOTE 1)	3/4"	12	12	12	20		0.800		20					SPARE		O	16
17	O	0.800	NAC PANEL INCTE 1	3/4"	12	12	12	20		0.800		20					SPARE		O	18
19	O		SPARE					20	0.000			20					SPARE		O	20
21	O		SPARE					20	0.000			20					SPARE		O	22
23	O		SPARE					20		0.000		20					SPARE		O	24
25	O		SPARE					20	0.000			20					SPARE		O	26
27	O		SPARE					20	0.000			20					SPARE		O	28
29	O		SPARE					20		0.000		20					SPARE		O	30
31	O		SPARE					20	0.000			20					SPARE		O	32
33	O		SPARE					20		0.000		20					SPARE		O	34
35	O		SPARE				20			0.000		20					SPARE		O	36
37	O		SPACE					20	0.000			20					SPACE		O	38
39	O		SPACE					20		0.000		20					SPACE		O	40
41	O		SPACE					20		0.000		20					SPACE		O	42
LOAD TOTAL:									2.23	2.35	2.40									
LOAD TYPE									CONNECTED			DEMAND								
(R) RECEPTACLES									2.92			100% 2.92								
(M) MOTOR									0.00			100% 0.00								
(H) HVAC									0.47			100% 0.47								
(L) LIGHTING									0.00			125% 0.00								
(O) OTHER									3.60			100% 3.60								
(K) KITCHEN EQUIP									0.00			100% 0.00								
TOTAL									6.99			100% 6.99								

NOTES:

1. PROVIDE RED BREAKER LOCK FOR FIRE ALARM CIRCUIT.

3.

4.

209Y110 V 3 PHASE 4 WIRE

MAINS: MLO 125 A BUS

2200V AIC SE LABEL

FED FROM: BL1

MOUNT: SURFACE

NEMA: 1

ELECTRICAL E606

PROVIDE DOOR WITH LOCK AND HINGED TRIM. PROVIDE COPPER BUSS BARS AND BOLT ON BREAKERS.

PANEL TOTALS

PHASE A	2.234	KVA	18.6	AMP
PHASE B	2.354	KVA	19.6	AMP
PHASE C	2.400	KVA	20.0	AMP



**Progressive Design Collaborative, Ltd.**  
3101 Poplarwood Court, Suite 320  
Raleigh, North Carolina 27604  
919-790-9989  
License# C-0183  
PROJECT #23015

**COOPER ACADEMY**  
**A & R**  
PROJECT TITLE




02/19/2024  
TBUTKOVICH@PDCENGINEERS.COM

1. THESE DRAWINGS ARE THE SOLE PROPERTY OF THE STATE OF NORTH CAROLINA. THE USE OF THESE DRAWINGS MUST COMPLY WITH G101 STATE OF NORTH CAROLINA STANDARD FORM OF AGREEMENT BETWEEN OWNER AND DESIGNER.

2. MATERIALS, DIMENSIONS AND ALL OTHER CONDITIONS WHICH ARE NOT OTHERWISE DEFINED ON THIS DRAWING SHALL BE CONSTRUED AS HAVING THE SAME MEANING AS SIMILARLY INDICATED CONDITIONS WHICH ARE MORE FULLY DEFINED ELSEWHERE ON THIS PROJECT OR OTHER DRAWINGS OF THIS PROJECT.

3. DO NOT SCALE OFF DIMENSIONS

REVISIONS 		
NO.	DATE	DESCRIPTION
1	02/20/2024	ADDENDUM 01

**BID SET**  
PROJECT PHASE

**2307**  
BOOMERANG DESIGN PROJECT NUMBER

**02.07.2024**  
DRAWING RELEASE DATE

# PANEL SCHEDULES

# E803

SHEET

2/19/2024 3:33:27 PM