



SHEET

1. FIRE PROTECTION FLOOR CONTROL VALVE ASSEMBLY, COORDINATE WITH FIRE PROTECTION CONTRACTOR.
2. SMOKE DETECTORS ARE REQUIRED IN EACH ELEVATOR LOBBY, MACHINE ROOM AND EACH SPRINKLER HEAD LOCATION IN HOISTWAY. ONLY THESE DETECTORS, WHEN ACTIVATED, SHALL PUT THE ELEVATOR IN FIREMANS RECALL OPERATION.
3. COORDINATE SPRINKLER BELL VOLTAGE WITH FIRE PROTECTION CONTRACTOR PRIOR TO ANY ROUGH-IN.
4. THESE HEAT DETECTORS SIGNAL THE SHUNT TRIP BREAKER TO TRIP REMOVING POWER TO THE ELEVATOR. THE ACTIVATION OF SMOKE DETECTORS REFERRED TO IN NOTE 2 CAPTURES THE ELEVATOR PRIOR TO THE ACTIVATION OF THE HEAT DETECTORS SO THAT THE LINE POWER IS REMOVED. ALL DETECTORS SHALL BE INSTALLED AT EACH SPRINKLER HEAD LOCATION.