


2/26/2024 3:46:12 PM



1 CONNECTOR SLAB PLAN
1/8" = 1'-0"

SLAB PLAN NOTES

- A. REFERENCE ARCHITECTURAL DRAWINGS FOR DIMENSIONS TO NONBEARING WALLS, WALL CONTROL JOINTS AND OPENINGS.
- B. ALL ELEVATIONS ARE BASED ON A REFERENCED FIRST FLOOR ELEVATION OF 0'-0" = 316.64' AND REFERENCED GROUND FLOOR ELEVATION OF -15'-4" = 301.30'. REFER TO ARCHITECTURAL DRAWINGS FOR FINISH FLOOR MATERIALS.
- C. REFERENCE ARCHITECTURAL DRAWINGS FOR EXACT LIMITS OF SLAB DEPRESSIONS AND OMITTED SLABS.
- D. FLOOR SINKS AND DRAINS ARE NOT SHOWN ON PLAN. REFERENCE PME DRAWINGS FOR LOCATIONS.
- E. REFERENCE CIVIL AND LANDSCAPE DRAWINGS FOR EXTERIOR CONCRETE SLABS AND PAVING.
- F. SLAB-ON-GRADE JOINTS MUST BE SAWED JOINTS OR KEYED CONSTRUCTION JOINTS, UNLESS OTHERWISE NOTED. CONTRACTOR MUST COORDINATE ALL SLAB JOINTS WITH JOINTS IN BONDED FLOOR FINISHES. REFERENCE ARCHITECTURAL DRAWINGS FOR FLOOR FINISH JOINT LOCATIONS.
- G. PLACE (1) #4 x 3'-0" IN MIDDLE OF SLAB AT RE-ENTRANT CORNERS WHERE A SLAB JOINT DOES NOT OCCUR.

KEY NOTES

- 01 4" CONCRETE SLAB-ON-GRADE OVER VAPOR RETARDER AND 4" DEPTH OF POROUS FILL UNLESS OTHERWISE INDICATED. REINFORCE SLAB WITH 6x6-W2.9xW2.9 WELDED WIRE REINFORCING PLACED 1 1/2" CLEAR BELOW TOP OF SLAB. MAINTAIN REINFORCEMENT IN POSITION ON BOLSTERS, CHAIRS OR SPACERS DURING CONCRETE PLACEMENT.
- 12 DEPRESSED SLAB AT ADA LIFT. REFERENCE ARCHITECTURAL DRAWINGS AND LIFT SUPPLIER FOR ADDITIONAL REQUIREMENTS.
- 38 REFERENCE TYPICAL STAIR ON GRADE DETAIL ON SHEET S502.
- 41 PROVIDE CONTROL JOINT AT RAMPS WHERE SLAB ON GRADE CHANGES IN SLOPE. TYPICAL.

boomerang
DESIGN
rethink, repurpose, results

SHS/BJ
201 S. Washington St., Suite 200
Jarvis, NC 28550
704/456-6000

CHARLOTTE
1230 W. Morehead St., Suite 214
Charlotte, NC 28208
704/731-7000

RALEIGH
6131 Falls of Neuse Rd., Suite 204
Raleigh, NC 27609
919/775-6400

LEWINGTON
1070 S. Lake Dr., Suite J
Lewington, NC 28753
803/754-0507

COOPER ACADEMY
A & R
PROJECT TITLE

02/26/2024

lynchmykins
EXCELUTE. COLLABORATE. CREATE.
Structural Engineers
301 N West St., Suite 105
Raleigh, NC 27603
919.782.1833 - lynchmykins.com
LM Project Number: LK21.298
Corporation No. C-4360

1. THIS DRAWING IS THE PROPERTY AND ©BOOMERANG DESIGN P.A. AND IS NOT TO BE REPRODUCED OR COPIED IN WHOLE OR IN PART. IT IS NOT TO BE USED ON ANY OTHER PROJECT AND IS TO BE RETURNED ON REQUEST.

2. MATERIALS, DIMENSIONS AND ALL OTHER CONDITIONS WHICH ARE NOT OTHERWISE SPECIFIED ON THIS DRAWING SHALL BE CONTROLLED AS HAVING THE SAME MEANING AS SIMILARLY INDICATED CONDITIONS WHICH ARE MORE FULLY DEFINED ELSEWHERE ON THIS PROJECT OR OTHER DRAWINGS OF THIS PROJECT.

3. DO NOT SCALE OFF DIMENSIONS.

REVISIONS		
NO.	DATE	DESCRIPTION
1	2/26/2024	ADDENDUM 2

CD
PERMIT SET
2307
BOOMERANG DESIGN PROJECT NUMBER
02.26.2024
DRAWING RELEASE DATE

**ALT. 2 CONNECTOR
SLAB PLAN**
SHEET TITLE

S132
SHEET