


5

4

3

2

2/13/2024 10:28:40 AM



1 FOUNDATION PLAN - SHOWER HOUSE

1/4" = 1'-0"

SHOWER HOUSE FOUNDATION / SLAB-ON-GRADE...

- REFER TO ARCHITECTURAL DRAWINGS FOR DIMENSIONS TO NONBEARING WALLS, WALL CONTROL JOINTS AND OPENINGS.
- UNLESS OTHERWISE NOTED, ALL ELEVATIONS ARE BASED ON A FINISHED FIRST FLOOR REFERENCE OF 0'-0". REFER TO ARCHITECTURAL DRAWINGS FOR FINISHED FLOOR MATERIAL.
- TOP OF ALL FOOTINGS MUST BE AT ELEVATION -1'-4" UNLESS OTHERWISE NOTED.
- NOT ALL UTILITY LOCATIONS ARE SHOWN ON PLAN. THE CONTRACTOR MUST COORDINATE THE LOCATIONS, SIZES, AND INVERTS OF UTILITIES. AT LOCATIONS WHERE UTILITIES PASS BELOW THE TOP OF FOOTING ELEVATION, STEP THE TOP OF FOOTING DOWN ON EACH SIDE PER THE "STEPPED FOOTING DETAIL" AND SLEEVE THE UTILITY THROUGH THE FOUNDATION WALL. THE CONTRACTOR MAY, AT THEIR OPTION, SLEEVE THE UTILITY THROUGH THE FOUNDATION PER THE "UTILITY SLEEVE DETAIL."
- UNLESS OTHERWISE INDICATED, EXTEND WALL FOOTINGS A MINIMUM OF 6 INCHES BEYOND ENDS OF WALLS.
- SLAB-ON-GRADE JOINTS MUST BE SAWED JOINTS OR KEYED CONSTRUCTION JOINTS UNLESS SPECIFICALLY DENOTED TO BE KEYED CONSTRUCTION JOINTS. CONTRACTOR MUST COORDINATE ALL SLAB JOINTS WITH JOINTS IN BONDED FLOOR FINISHES. REFER TO ARCHITECTURAL DRAWINGS FOR FLOOR FINISH JOINT LOCATIONS.
- PLACE 1 - #4 x 3'-0" IN MIDDLE OF SLAB AT REENTRANT CORNERS WHERE A SLAB CONTROL JOINT DOES NOT OCCUR.
- REFER TO ARCHITECTURAL DRAWINGS FOR EXACT LIMITS OF SLAB DEPRESSIONS.
- FLOOR DRAINS AND FLOOR SINKS ARE NOT SHOWN ON PLAN. REFER TO PLUMBING DRAWINGS FOR LOCATIONS.
- REFER TO CIVIL DRAWINGS FOR EXTERIOR CONCRETE SLABS AND PAVING.
- GRID LINES AT EXTERIOR WALLS REPRESENT OUTSIDE FACE OF CMU / OUTSIDE FACE OF PLYWOOD SHEATHING.

KEY NOTES

COLUMN FOOTING SCHEDULE					
MARK	SIZE		REINFORCING		
	LENGTH	WIDTH	DEPTH	BOTTOM	TOP
CF3.5	3' - 6"	3' - 6"	1'-0"	#5 AT 12" OC EW	#5 AT 12" OC EW
CF5	5' - 0"	5' - 0"	1'-0"	#5 AT 12" OC EW	#5 AT 12" OC EW
CF7x3	3' - 0"	7' - 0"	1'-0"	#5 AT 12" OC EW	#5 AT 12" OC EW

WALL FOOTING SCHEDULE				
MARK	SIZE		REINFORCING	
	WIDTH	DEPTH	CONTINUOUS	TRANSVERSE
WF3	3' - 0"	1'-0"	(4) #4 BOT	#4 AT 48" OC BOT
WF5	5' - 0"	1'-0"	(6) #4 BOT	#4 AT 48" OC BOT

MASONRY WALL REINFORCING SCHEDULE		
MARK	CMU	VERTICAL REINFORCING
M1	8"	#6 AT 8" OC
M2	8"	#6 AT 32" OC



Structural Engineers
301 N West St., Suite 105
Raleigh, NC 27603
919.782.1833 - lynchmykins.com

project status


Construction Documents

owner id

SCO ID#

16-14421-01A

seals



revisions

#	date	note
1	01-19-24	
2	02-15-24	ADD 2

Umstead State Park Campground
Improvements
8801 Glenwood Ave
Raleigh, NC 27617
NC Division of Parks and Recreation

PROJECT 1394-21
DATE 02/12/2024
DRAWN PS
CHECKED JRM

sheet name

FOUNDATION
PLAN - SHOWER
HOUSE

sheet no

SSIII