



Progressive Design Collaborative, Ltd

3101 Poplarwood Court, Suite 320

Raleigh, North Carolina 27604

919-790-9989

ADDENDUM 01 – FIRE PROTECTION

DATE: February 19, 2024

PROJECT: Cooper Academy Elementary School Addition and Renovation
PDC Project No. 23015

This Addendum, applicable to the work designed below, shall be understood to be and is a change to the bid documents and shall be part of and included in the contract for the above referenced project. All General, Supplementary and Special Conditions, etc., as originally specified or as modified below shall apply to these items.

Changes to Fire Protection Drawings:

1. Drawing FP102
 - a. Added zone for book storage to be ordinary hazard group 1 coverage.

END OF ADDENDUM 01 – FIRE PROTECTION

Attachments: As listed above



pdcengineers.com



Progressive Design Collaborative, Ltd

3101 Poplarwood Court, Suite 320

Raleigh, North Carolina 27604

919-790-9989

ADDENDUM 01 – PLUMBING

DATE: February 19, 2024

PROJECT: Cooper Academy Elementary School Addition and Renovation
PDC Project No. 23015



This Addendum, applicable to the work designed below, shall be understood to be and is a change to the bid documents and shall be part of and included in the contract for the above referenced project. All General, Supplementary and Special Conditions, etc., as originally specified or as modified below shall apply to these items.

Changes to Plumbing Specifications:

1. Section 22 05 63
 - a. Added this Section

Changes to Plumbing Drawings:

2. Drawing P202
 - b. Added RP-1 to floor plan and Gas piping drop to water heater.
2. Drawing P302
 - a. Added Gas riser and gas piping table. Added tag for water hammers and hose bibbs in equipment platform.
3. Drawing P501
 - a. Revised water heater detail to remove storage tank.
4. Drawing P601
 - a. Revised water heater schedule to remove storage tank.

END OF ADDENDUM 01 – PLUMBING

Attachments: As listed above



pdcengineers.com



ADDENDUM 01 – ELECTRICAL

DATE: February 19, 2024

PROJECT: Cooper Academy
PDC Project No. 23015

This Addendum, applicable to the work designed below, shall be understood to be and is a change to the bid documents and shall be part of and included in the contract for the above referenced project. All General, Supplementary and Special Conditions, etc., as originally specified or as modified below shall apply to these items.

Changes to Electrical Drawings:

1. Drawing E001
 - a. Revise: General note 6.
2. Drawing E101
 - a. Revise: Relocate Fire Alarm Equipment to Elec 606, Keynotes 11, 12 and 13.
 - b. Clarified: Elevator Disconnects and Telephone interface in Data 605.
 - c. Added: General Note F.
3. Drawing E102
 - a. Revise: Keynotes 15, 16 and 17, Elevator Hoist-way electrical devices.
4. Drawing E103
 - a. Added: General Note E.
5. Drawing E202
 - a. Added: Lights in Elevator Hoist-way machinery space, Keynotes 6 & 7.
6. Drawing E301
 - a. Revise: Elevator Hoist-way and Data 605 background devices.
7. Drawing E302
 - a. Revise: Elevator Hoist-way and Data 605 background devices.
8. Drawing E401
 - a. Revise: Relocate Fire Alarm Equipment to Elec 606.
 - b. Added: Keynote 3.



9. Drawing E402
 - a. Revise: Pull-station location corridor C500B.
 - b. Deleted: Heat Detector Corridor C501.
 - c. Added: Keynote 4.
10. Drawing E503
 - a. Revise: FACP-2 Room reference in the Fire Alarm Riser.
11. Drawing E505
 - a. Added: Security Intrusion System Riser.
12. Drawing E700
 - a. Revise: Keynote 2.
 - b. Added: Keynotes 6 & 7, cross reference to notes on plan.
13. Drawing E701
 - a. Added: Keynotes 8 & 9, cross reference notes on plans and General Note E.
14. Drawing E704
 - a. Revised Pull-station location.
15. Drawing E802
 - a. Revise: Panel Schedules MDP, AH1 and AL2.
16. Drawing E803
 - a. Revise: Panel Schedule BH, BL2, BL3, CH1 and JL.
17. Drawing E804
 - a. Revise: Panel Schedule ZL.

END OF ADDENDUM 01 – ELECTRICAL

Attachments: See Drawing listing above