


**SLAB PLAN NOTES**

- A. REFERENCE ARCHITECTURAL DRAWINGS FOR DIMENSIONS TO NONBEARING WALLS, WALL CONTROL JOINTS AND OPENINGS.
- B. ALL ELEVATIONS ARE BASED ON A REFERENCED FIRST FLOOR ELEVATION OF 0'-0" = 316.64' AND REFERENCED GROUND FLOOR ELEVATION OF -15'-4" = 301.30'. REFER TO ARCHITECTURAL DRAWINGS FOR FINISH FLOOR MATERIALS.
- C. REFERENCE ARCHITECTURAL DRAWINGS FOR EXACT LIMITS OF SLAB DEPRESSIONS AND OMITTED SLABS.
- D. FLOOR SINKS AND DRAINS ARE NOT SHOWN ON PLAN. REFERENCE PME DRAWINGS FOR LOCATIONS.
- E. REFERENCE CIVIL AND LANDSCAPE DRAWINGS FOR EXTERIOR CONCRETE SLABS AND PAVING.
- F. SLAB-ON-GRADE JOINTS MUST BE SAWED JOINTS OR KEYED CONSTRUCTION JOINTS, UNLESS OTHERWISE NOTED. CONTRACTOR MUST COORDINATE ALL SLAB JOINTS WITH JOINTS IN BONDED FLOOR FINISHES. REFERENCE ARCHITECTURAL DRAWINGS FOR FLOOR FINISH JOINT LOCATIONS.
- G. PLACE (1) #4 x 3'-0" IN MIDDLE OF SLAB AT RE-ENTRANT CORNERS WHERE A SLAB JOINT DOES NOT OCCUR.

**KEY NOTES**

- 01 4" CONCRETE SLAB-ON-GRADE OVER VAPOR RETARDER AND 4" DEPTH OF POROUS FILL UNLESS OTHERWISE INDICATED. REINFORCE SLAB WITH 6x6-W2.9xW2.9 WELDED WIRE REINFORCING PLACED 1 1/2" CLEAR BELOW TOP OF SLAB. MAINTAIN REINFORCEMENT IN POSITION ON BOLSTERS, CHAIRS OR SPACERS DURING CONCRETE PLACEMENT.
- 02 2 1/2" CONCRETE SLAB ON 1 1/2" FLOOR DECK. 4" TOTAL REINFORCED WITH 6x6-W2.9xW2.9 WELDED WIRE REINFORCING. WELDED WIRE REINFORCING LOCATED 1" CLEAR BELOW TOP OF SLAB.
- 18 CANOPY BY OTHERS. MAX WEIGHT 15 PSF.
- 33 REFERENCE THICKENED SLAB TYPICAL DETAIL AT INTERIOR NON-BEARING MASONRY WALL.



02/26/2024

**lynchmykins**  
Structural Engineers  
301 N West St., Suite 105  
Raleigh, NC 27603  
919.782.1832 - lynchmykins.com  
LM Project Number: LK21.298  
Corporation No. C-4360

- 1. THIS DRAWING IS THE PROPERTY OF BOOMERANG DESIGN P.A. AND IS NOT TO BE REPRODUCED OR COPIED IN WHOLE OR IN PART. IT IS NOT TO BE USED ON ANY OTHER PROJECT AND IS TO BE RETURNED ON REQUEST.
- 2. MATERIALS, DIMENSIONS AND ALL OTHER CONDITIONS WHICH ARE NOT OTHERWISE SPECIFIED ON THIS DRAWING SHALL BE CONTROLLED BY HAVING THE SAME MEANING AS SIMILARLY INDICATED CONDITIONS WHICH ARE MORE FULLY DEFINED ELSEWHERE ON THIS PROJECT OR OTHER DRAWINGS OF THIS PROJECT.
- 3. DO NOT SCALE OFF DIMENSIONS.

NO.	DATE	DESCRIPTION
1	2/26/2024	ADDENDUM 2

**CD**  
PERMIT SET  
**2307**  
BOOMERANG DESIGN PROJECT NUMBER  
**02.26.2024**  
DRAWING RELEASE DATE

2/26/2024 3:45:57 PM