

WCPSS - Swift Creek Elementary School
RFIs

TO: James Johnston
Senior Project Manager
LS3P
Email: jamesjohnston@ls3p.com

No.	Scope	Ref. Dwg.	Question	Asked by:	Date	Response	Assigned/ Response:	R. Date	Issued on
1	General	Bid Form	The bid form refers to DBE goals. Will the project be tracking DBE participation but not HUB participation?	Sterling Construction	4/18/2024	The Bid Form had a typo, this is a HUB project. Form has been updated and the old one deleted to try to avoid confusion.	JE Dunn	4/18/2024	Addendum 2
2	General	SOW	Where are the Scopes of work?		4/18/2024	Scopes of work will be shared via addendum on Monday 04/22/2024	JE Dunn	4/18/2024	Addendum 2
3	General	RFIs	When is the last day to submit RFIs?		4/18/2024	RFIs are due 4/26/2024	JE Dunn	4/18/2024	Addendum 2
4	31C Earthwork	CAD	Are the CAD drawigns available for the Earthwork bidders?	Sullivan Eastern	4/18/2024	Yes, they have been transferred to JE Dunn for Distribution	McAdams	4/22/2024	Addendum 2
5	09A Framing	B2/S03.23	On detail B2/S03.23 and other typical parapet details show the bar joist truss setting on the structural I beam and attaching the parapet with a stiff clip. This causes the bottom track to be cut into 5' pieces to fit in between the bar joists and only a stiff clip to support the parapet. This will cause engineering conflicts that will prevent meeting the wind loads.	Grey Interiors	4/19/2024		LS3P		
6	06E Casework	123216	A substitution request has been submitted for casework to use Case Systems. Please advise if this is acceptable	Nycom	4/19/2024	No exceptions taken with substitution request.	LS3P	4/22/2024	Addendum 2