


01 FLOOR 1 - MECHANICAL NEW PIPING PLAN
SCALE: 3/16" = 1'-0"

- GENERAL NOTES:
- CONTRACTOR SHALL FIELD VERIFY LOCATION AND SIZES OF ALL EQUIPMENT AND PIPING IN THIS SPACE PRIOR TO FABRICATION.

- KEYED NOTES
- REFER TO DETAIL 03/M5.02 FOR DETAILED INSTRUCTIONS ON INSTALLATION OF HEAT EXCHANGER COMPONENTS.
 - REFER TO DETAIL 01/M5.02 FOR DETAILED INSTRUCTIONS ON INSTALLATION OF STACKED INLINE HOT WATER PUMPS
 - REFER TO PIPING SCHEMATICS, SHEET M4.00 FOR FURTHER INFORMATION ABOUT HOT WATER PIPING COMPONENTS.
 - TURN NEW 1/2" HWS/R UP INTO NEW MECHANICAL ROOM ABOVE.
 - ALL MATERIALS INSTALLED IN MECHANICAL ROOM 104 SHALL BE PLENUM-RATED.
 - INSTALL NEW TRANE FCD020 OR EQUAL COOLING ONLY 6,000 BTU 200CFM HORIZONTAL 120V CABINET FAN COIL UNIT ABOVE DOOR IN EQUIPMENT ROOM. ROUTE CONDENSATE BACK TO HUB DRAIN IN MECH 104.



02 MECHANICAL BASEMENT NEW PIPING PLAN
SCALE: 1/4" = 1'-0"

FIRE RATED WALL LEGEND	
	1 HR FIRE BARRIER
	2 HR FIRE BARRIER

1 ADDENDUM #1

