

**Tammy Lynn Phase II
RFI LOG**

#	Trade	Question	Page/Spec	Date Submitted	Date Answered	Response
1	Window Treatments	Civitan Building - Huddle Room on A110 - There is a window that isnt labeled. Is it safe to assume this to be W01 and it will received a roller shade? Room 109 - It shows two W04s and that only one gets roller shades. Is it safe to assume both will get roller shades? Should all Residential Rooms be considered ADA?	A110	11/18/2024	11/19/2024	That is correct that both windows in A110 are W01. Also correct that both W04s should have manual roller shades. And yes, all resident rooms should be considered ADA.
2	Demo	Please clarify the extend of demo to the cermaic wall tile in bathrooms 105 & 118	A100	11/25/2024	11/25/2024	Floor and wall tile is to be removed. We plan to replace drywall behind the demo'd wall tile. Floor tile is assumed to be on thin set. Please include demo of tile and thinset.
3						
4						
5						
6						
7						
8						
9						
10						
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						
21						
22						
23						