
SECTION 260500 - BASIC ELECTRICAL REQUIREMENTS

PART 1 - GENERAL

RELATED DOCUMENTS

Drawings and general provisions of Contract, including General and Supplementary Conditions and Division-1 Specification sections, apply to work of this section.

SCOPE

The electrical design for this project is based on the requirements of the *National Electrical Code (NEC)*, NFPA-70, 2020 Edition. Where not restricted to more stringent requirements by the Drawings and Specifications, the minimum requirements of the NEC shall prevail.

DEFINITIONS

Labeled: Equipment or materials to which has been attached a label, symbol, or other identifying mark of an organization accredited by NCBCC (North Carolina Building Code Council) to label electrical equipment and concerned with product evaluation, that maintains periodic inspection of production of labeled equipment or materials and by whose labeling the manufacturer indicates compliance with appropriate standards or performance in a specified manner.

Listed: Equipment or materials included in a list published by an organization accredited by NCBCC (North Carolina Building Code Council) to label electrical equipment and concerned with product evaluation, that maintains periodic inspection of production of listed equipment or materials, and whose listing states either that the equipment or material meets appropriate designated standards or has been tested and found suitable for use in a specified manner.

PART 2 – PRODUCTS (NOT USED)

PART 3 - EXECUTION

DUTIES OF CONTRACTOR

The Drawings are generally diagrammatic in nature and are neither intended to show each fitting, box, elbow, offset, hanger, *etc.*, nor a complete detail of all work to be done. The Drawings are for the purpose of illustrating the type of system, showing raceway sizes, *etc.*, and special conditions considered necessary for the experienced mechanic to take off materials and lay out work. This Contractor shall be responsible for taking such measurement as may be necessary at the job and adapting his work to local conditions.

SUBMITTALS

Submittals shall be made in strict accordance with the requirements of Section 019913. Specific submittal requirements are defined in each section of this Division.

Manufacturer's Data: Submit manufacturer's technical product data.

1 **NAMEPLATE DATA**

2
3 Each item of electrical utilization equipment shall be provided with a permanent operational data nameplate that shall,
4 as a minimum, indicate the following: equipment manufacturer, product name, model number, serial number,
5 capacity, voltage requirements, and either full load current or full load volt-amperes. Labels of tested compliances
6 and similar essential data shall be a part of this label or located nearby. All equipment nameplates shall be in an
7 accessible location.

8
9 In the event that the installation of equipment renders the manufacturer's nameplate inaccessible, the above
10 information shall be etched onto a laminated plastic nameplate securely fastened to the equipment by no less than
11 two machine screws or by other fastening methods approved by the A-E.

12
13
14 **FLASH PROTECTION WARNING**

15
16 Each piece of new electrical equipment, such as switchboards, parallel switchgear, panelboards, circuit breaker
17 enclosures, control panels, motor control centers, transfer switches, etc. that are likely to require examination,
18 adjustment, servicing or maintenance while energized, shall be field marked in a clearly visible location on the
19 equipment enclosure to warn qualified persons of potential electric arc flash hazards, in accordance with NEC
20 110.16.

21
22
23 **TESTING LABORATORY APPROVAL**

24
25 All equipment shall be approved for the intended use and shall be Labeled or Listed. In any case where the suitability
26 for a particular application is in question by the A-E or inspection authorities the Contractor shall furnish appropriate
27 standards covering the specific piece of equipment in question. Such standards, if required, shall be requested by
28 the A-E in writing and shall be furnished by the Contractor at no additional cost.

29
30
31 **END OF SECTION 260500**