


ADDENDUM 2			
PROJECT:		THALES CLAYTON #4	
ADDRESS:		109 SE FLOWERS PARKWAY, CLAYTON, NC	
DATE ISSUED:		2/24/25	
ADDENDUM #	ITEM #	ITEM DESCRIPTION	RESPONSE
1	1	OWNERS' NOTE	UPDATED CUT SHEETS FOR GRAVITY VENTS TO BE INSTALLED AT EXISTING K5, HIGH SCHOOL AND GYM.
	2	DOES THIS BUILDING CONNECT ANY OTHERS VIA CONDUIT?	YES. THERE IS CAMERA FIBER RUNNING AROUND THE PERIMETER OF THE SITE. PLAN IS TO USE ONE OF THE CAMERA POLES THAT WILL BE DEMO'D AND TIE IN OFF THAT PULL BOX.
	3	WHERE WILL THE NEW TRANSFORMER BE LOCATED?	PLAN EAST, ACROSS THE DRIVE ISLE FROM THE BUILDING. SEE ATTACHED.
	4	WILL ANY NEW SITE LIGHTING BE INSTALLED? DEMO PLANS SAYS TO RELOCATE	YES. (4) LIGHTS ARE TO BE DEMO'D AND (6) ADDED AROUND DRIVE PERIMETER. SEE ATTACHED.
	5	WOULD IT BE OKAY TO POUR HANDICAP SPOTS IN CONCRETE IN LIEU OF ASPHALT?	YES, OK TO SUB FOR CONCRETE.
	6	WHAT WILL THE TRAFFIC PATTERN BE DURING CNSTRUCTION?	THERE MUST BE NO INTERRUPTIONS TO SCHOOL OPERATIONS. PLEASE SUBMIT PHASING PLAN FOR APPROVAL.
2	7	OWNERS' NOTE	ATTACHED ARE CAPTIVEAIRE HVAC EQUIPMENT SHOP DRAWINGS.
	9	OWNERS' NOTE	UPDATED CIVIL PLAN SHOWING FINAL TRANSFORMER LOCATION. PLEASE DISREGARD THE SKETCH SHOWING IT ACROSS THE DRIVE ISSUED IN ADDENDUM 1.
	10	OWNERS' NOTE	ATTACHED ACADEMIC CALENDAR FOR THE COMING YEAR. IT CAN ALSO BE FOUND AT https://www.thalesacademy.org/parents/academic-calendar
	11	IS THERE A LANDSCAPING PLAN?	NO LANDSCAPE PLANTING REQUIRED. SOD ALL DISTURBED AREAS WITH TIFTUF BERMUDA SOD.
	12	PLEASE CLARIFY WHICH PAVING AREAS ARE HEAVY/LIGHT DUTY.	ALL PAVING IS 3 OVER 8. # "TYPE SF9.5B OVER 8" CABC.
	13	CAN YOU PROVIDE A CURRENT TRAFFIC PLAN THE SCHOOL USES FOR PICKUP/DROPOFF?	PLEASE SEE ATTACHED WITH TIMES.
	14	PDF VERSION OF GEOTECH REPORT (THE SHEETS INSERTED INTO THE DRAWINGS ARE NOT LEGIBLE).	ATTACHED.
	15	DO WE NEED TO CARRY ANY ADDITIONAL INCIDENTALS? BACKGROUND CHECKS, DRUG TESTING, FULL SAFETY REP., SECURITY, ETC.?	NO.

PLEASE CLARIFY THE EXISTING STORM PIPE.



This pipe “does this get demoed” – it does not exist. Shown in error on the survey/demo plan. The GREEN line is correct/ the one in the field. Do not disturb the GREEN line. No. Convert to JB. Solid Round top is fine. No need to be CB.